

1920 Portal St.
Baltimore, MD 21224



Phone: 410-633-0685
Fax: 410-633-0683
www.wemakeduct.com

Security Bar Specifications

Bars: $\frac{1}{2}$ " Cold Rolled Bar, Welded on 6" centers. ASTM A-36

- All intersections to be mig welded $\frac{3}{16}$ " both horizontal and vertical.

- Brinell Rating is 1163

Frame: $\frac{1}{4}$ " thick x 1.5" wide black iron. ASTM A-36 corners welded.

- Frames are undersized $\frac{1}{4}$ " to accommodate duct size.

